

DECLARATION OF PERFORMANCE

According to Construction Products Regulation

No.

DOP 22-005 (0832-UKCA-CPR-F1438)

1. Unique Product identification code:

CBE6-RS-024-EN	CBE6-WS-024-EN	CBE6-GS-024-EN
CBE6-RD-024-EN	CBE6-WD-024-EN	CBE6-GD-024-EN
CBE6-RW-024-EN	CBE6-WW-024-EN	CBE6-GW-024-EN
CBE6-RS-024-SV	CBE6-WS-024-SV	CBE6-GS-024-SV
CBE6-RD-024-SV	CBE6-WD-024-SV	CBE6-GD-024-SV
CBE6-RW-024-SV	CBE6-WW-024-SV	CBE6-GW-024-SV

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

CBE6-RS-024-EN – Clambell 24V Red 6” Fire Alarm bell, Shallow base, English
CBE6-RD-024-EN – Clambell 24V Red 6” Fire Alarm bell, Deep base, English
CBE6-RW-024-EN – Clambell 24V Red 6” Fire Alarm bell, Weatherproof base, English
CBE6-WS-024-EN – Clambell 24V White 6” Fire Alarm bell, Shallow base, English
CBE6-WD-024-EN – Clambell 24V White 6” Fire Alarm bell, Deep base, English
CBE6-WW-024-EN – Clambell 24V White 6” Fire Alarm bell, Weatherproof base, English
CBE6-GS-024-EN – Clambell 24V Grey 6” Fire Alarm bell, Shallow base, English
CBE6-GD-024-EN – Clambell 24V Grey 6” Fire Alarm bell, Deep base, English
CBE6-GW-024-EN – Clambell 24V Grey 6” Fire Alarm bell, Weatherproof base, English
CBE6-RS-024-SV – Clambell 24V Red 6” Fire Alarm bell, Shallow base, Swedish
CBE6-RD-024-SV – Clambell 24V Red 6” Fire Alarm bell, Deep base, Swedish
CBE6-RW-024-SV – Clambell 24V Red 6” Fire Alarm bell, Weatherproof base, Swedish
CBE6-WS-024-SV – Clambell 24V White 6” Fire Alarm bell, Shallow base, Swedish
CBE6-WD-024-SV – Clambell 24V White 6” Fire Alarm bell, Deep base, Swedish
CBE6-WW-024-SV – Clambell 24V White 6” Fire Alarm bell, Weatherproof base, Swedish
CBE6-GS-024-SV – Clambell 24V Grey 6” Fire Alarm bell, Shallow base, Swedish
CBE6-GD-024-SV – Clambell 24V Grey 6” Fire Alarm bell, Deep base, Swedish
CBE6-GW-024-SV – Clambell 24V Grey 6” Fire Alarm bell, Weatherproof base, Swedish

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and alarm systems in and around buildings

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Vimpex Ltd, Star Lane, Great Wakering, Essex, SS3 0PJ, UK

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

LPCB – Notified Body No. F1438

Performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

0832-UKCA-CPR-F1438

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable


9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3 have been determined as described in the hEN mentioned in the following table:

Essential characteristics	Performance	Harmonized Technical Specification EN 54-3:2001 +A1 +A2
Performance under fire condition	Pass	4.2, 4.3, 5.2, 5.3
Operational reliability	Pass	4.4, 4.5, 4.6, 5.4
Durability of operational reliability: temperature resistance	Pass	5.5, 5.6, 5.7, 5.8, 5.9
Durability of operational reliability: humidity resistance	Pass	5.8, 5.9, 5.10
Durability of operational reliability: corrosion resistance	Pass	5.11
Durability of operational reliability: shock and vibration resistance	Pass	5.12 to 5.15
Durability of operational reliability: resistance to ingress	Pass	5.17

10. The performance of the product identified in 1 and 2 is in conformity with the declared performance in 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of Vimpex Ltd:

Name: Mr James Jones
Position: Managing Director
Signature: 
Date: 31/08/2022